

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0587:121

Page 1 of 1

CATEGORY: Audible Signal Device

LISTEE: American Security Equipment Co., Division of Kobishi America Inc., 228 E. Star of India Lane, Carson CA 90746 Contact: Toby Tabata (310) 538-4670 FAX (310) 538-9932

DESIGN: Models HP-25T and HP-26 audible signal appliances. Intended for installation in a suitable single-gang electrical box. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 VDC = HP-25T 24 VDC nominal
96-132 VAC = HP-26 120 VAC nominal

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as audible signal appliances for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Model HP-25T employs a selectable temporal tone. Model HP-26 requires the use of AMESCO Model TMP1-3B temporal module.

11-06-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **NOVEMBER 6, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**